


**Lesson 1a: Mixed use model with load calculations – Design Alternative**

1	Click on the <b>File</b> Menu											
2	Click on the New Menu-Button to create a new project.											
3	In the <b>Project</b> workspace											
4	In the Project Information palette											
5	For <b>Design Alternative 1</b> , set the <b>Region</b> dropdown to	"CA"										
6	Set the <b>Location</b> dropdown to (or type in "San F" to filter the list) This loads the weather data for the project.	"San Francisco Intl Ap"										
7	Rename the <b>Design Alternative 1</b> to	"Load calculation"										
<div style="border: 1px solid #ccc; padding: 5px;"> <p><b>Create/Edit Design Alternatives</b> <span style="float: right;">New Copy Validate Model Delete</span></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Name</th> <th>Description</th> <th>Weather Source</th> <th>Region</th> <th>Location</th> </tr> </thead> <tbody> <tr> <td> Load calculation</td> <td>Automatically generated Baseli...</td> <td>Standard</td> <td>CA</td> <td>San Francisco Intl Ap</td> </tr> </tbody> </table> </div>			Name	Description	Weather Source	Region	Location	Load calculation	Automatically generated Baseli...	Standard	CA	San Francisco Intl Ap
Name	Description	Weather Source	Region	Location								
Load calculation	Automatically generated Baseli...	Standard	CA	San Francisco Intl Ap								
8	Go to the <b>Buildings</b> Workspace											
9	In the <b>Create/Edit Buildings</b> ribbon menu											
10	In the <b>Create/Edit Building</b> palette											
11	Click on the <b>Building Sections</b> tab											
12	Select <b>Section Type</b> dropdown as		"Retail Building Section Type"									
13	Click on <b>Save Section</b>											
14	Click on the <b>Building Stories</b> tab											
15	Click the <b>New Stories</b> button											
16	Change <b>Num of Stories</b> to	2										
17	Select the <b>Shape</b> dropdown as	"U-shape"										
18	Select the <b>Occupied Configuration</b> dropdown as	"One Zone Per Floor"										
19	Set <b>Shape Parameter X1</b> to	120 ft      36 m										
20	Check the <b>Flip X</b> checkbox											
21	Set <b>Floor to Floor</b> to	16 ft      4.8 m										
22	Set <b>Ceiling Elevation</b> to	13 ft      4 m										

Buildings | Building Sections | Building Stories | Glazing | Roof

Building Section: Building Section (A.A)

Building Story Type: Retail Building Story Type Edit

Base Story:  Num of Stories:

Shape: U Shape

Plenum Configuration: No Plenum

Occupied Configuration: One Zone per Story

Ceiling Configuration: Same As Occupied

Floor Configuration: Same As Occupied

Floor to Floor:  ft  
 Above Ceiling Height:  ft  
 Ceiling Elevation:  ft  
 Top of Floor Elevation:  ft  
 Below Floor Height:  ft  
 Perimeter Zone Depth:  ft  
 Floor Area:  ft<sup>2</sup>  
 Floor Perimeter:  ft


**Shape Parameters**

X1:  ft    Y1:  ft    X:  ft


X2:  ft    Y2:  ft    Y:  ft

X3:  ft    Y3:  ft    Z:  ft

Flip X     Flip Y    Rot:  °



3D view of building section showing Ceiling Void and Space/Thermal Zone.



2D U-shaped floor plan diagram with dimensions X-1, X-2, X-3, Y-1, Y-2.

23	Click on the <b>Glazing</b> tab	
24	Change the <b>Calculation Method</b> to	<i>Percentage</i>
25	Set <b>Target Win/Wall Ratio</b> (for all orientations) to	<i>"50%"</i>
26	Set <b>Win Top Elevation</b> (for all orientations) to	<i>12 ft</i> <i>3.6 m</i>
27	Click on <b>Save Stories</b>	

Buildings Building Sections Building Stories **Glazing** Roof

Arrays: One Window Array Calculation Method: Percentage

**Array One** Window Type: Default By Orientation Overhang Type: Overhang (1.5) Fin Type: Fin (1.5 ft)

Window Orientation	Strip	Target Win/Wall Ratio	Win Top Elevation	Window Width	Window Height	Window Minimum Gap	Window Offset From Left	Window Offset From Right	Exterior Shading			
									Horiz.	Cont.	Fin L R	
North	<input type="checkbox"/>	50%	12.00 ft	10.00 ft	6.50 ft	2.00 ft	2.00 ft	2.00 ft	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
South	<input type="checkbox"/>	50%	12.00 ft	10.00 ft	6.50 ft	2.00 ft	2.00 ft	2.00 ft	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
East	<input type="checkbox"/>	50%	12.00 ft	10.00 ft	7.31 ft	2.00 ft	2.00 ft	2.00 ft	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
West	<input type="checkbox"/>	50%	12.00 ft	10.00 ft	7.31 ft	2.00 ft	2.00 ft	2.00 ft	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**Lesson 1b: Mixed use model with load calculations – 2<sup>nd</sup> building section**

28	In the <b>Buildings</b> Workspace	
29	In the <b>Create/Edit Buildings</b> ribbon menu	
30	In the <b>Create/Edit Building</b> palette	
31	Click on the <b>Building Sections</b> tab	
32	Click on <b>New Section</b>	
33	Select the <b>Section Type</b> dropdown as	<i>"Office Building Section Type"</i>
34	Click on <b>Save Section</b>	
35	Click on the <b>Building Stories</b> tab	
36	Click the <b>New Stories</b> button	
37	Change <b>Num of Stories</b> to	<i>4</i>
38	Select the <b>Shape</b> dropdown as	<i>"Rectangle shape"</i>
39	Select the <b>Occupied Configuration</b> dropdown as	<i>"One Zone Per Floor"</i>
40	Set <b>Shape Parameter X1</b> to	<i>120 ft</i> <i>36 m</i>
41	Set <b>Shape Parameter Y1</b> to	<i>40 ft</i> <i>12 m</i>
42	Set <b>Origin X</b> to	<i>40 ft</i> <i>12 m</i>
43	Set <b>Origin Y</b> to	<i>110 ft</i> <i>33 m</i>
44	Click on <b>Save Stories</b>	

Buildings Building Sections Building Stories **Glazing** Roof

Building Section: Building Section (A.B)

Building Story Type: Office Building Story Type Edit

Base Story: 1 Num of Stories: 4

Shape: Rectangle Shape X1: 120.00 ft Y1: 40.00 ft X: 50.00 ft

Plenum Configuration: No Plenum X2: ft Y2: ft Y: 110.00 ft

Occupied Configuration: One Zone per Story X3: ft Y3: ft Z: ft

Ceiling Configuration: Same As Occupied  Flip X  Flip Y Rot: 0.0 °

Floor Configuration: Same As Occupied

Floor to Floor: 13.00 ft

Above Ceiling Height: 2.60 ft

Ceiling Elevation: 10.00 ft




Top of Floor Elevation: 0.00 ft

Below Floor Height: 0.00 ft













Perimeter Zone Depth: 15.00 ft

Floor Area: 4800.00 ft<sup>2</sup>

Floor Perimeter: 320.00 ft


45	Go to the <b>Systems</b> Workspace	
46	In the <b>Systems Creator</b> ribbon menu	
47	Select the <b>Template Name</b> dropdown as	<i>“Default Loads calculation”</i>
48	Set the radio button for Zone HVAC Groups to	<i>“One per building”</i>
49	Click on <b>Generate Systems</b>	
		
50	Go to the <b>Simulate</b> Workspace	
51	In the <b>EnergyPlus</b> ribbon menu	
52	In the lower left palette	
53	Click on <b>New Configuration</b>	
54	Select the <b>Simulation Parameter</b> template dropdown as <i>For the load calculations (sizing) we do not necessarily need the annual run, but since we want to compare results of annual runs later, we are selecting a full annual run here.</i>	<i>“Full 2019 with design days”</i>
55	Select the <b>Request Set Parameter</b> template dropdown as	<i>“System Variables – Detailed Set w/Zones + Meters”</i>
		
56	Click on the <b>File</b> Menu	
57	Click on the <b>Save</b> Button to save the current model.	
58	Set <b>File name</b> to	<i>“BasicTraining1”</i>
59	In the <b>Simulate</b> Workspace	
60	In the <b>EnergyPlus</b> ribbon menu	
61	In the lower right palette	
62	Click on <b>Run Simulation</b> – watch the progress bar and progress messages thereafter (Step 1: Simulation preparation, Step 2: Simulation) <i>The Simergy UI is disabled for a short period of time. After that the simulation and its preparation runs in the background and Simergy is enabled again.</i>	
63	Wait for simulation to finish and click on the <b>Results</b> button in the SimRun1 row	
		
64	In the <b>Reports</b> Workspace	
65	Select the <b>Zone Summary</b> Report (the default report Project Summary is loaded first)	
66	In the <b>Zone Summary</b> report, the first section Zone Summary gives an overview of basic parameters per zone (such as area and volume) but also feedback on the internal loads defined. The second section contains the design day sizing results and we can look at the calculated loads on a per zone basis. Zone loads for the retail spaces are higher the loads for the office spaces.	

**Design Day: Zone Cooling (1%) and Heating (99%)**


		Calculated Design Load (Btu/h)	User Design Load (Btu/h)	Calculated Design Air Flow (cfm)	User Design Air Flow (cfm)	Date of Peak	External Temperature at Peak (°F)	Humidity Ratio at Peak (lb-H <sub>2</sub> O/lb-air)	Calculated Cooling Load (Btu/h)		Calculated Heating Load (Btu/h)	
									Min	Max	Min	Max
THERMAL ZONE A-1-1	Cooling	239,330.5	275,230.1	9,594.3	11,033	8/21 09	69.84	0.00819	0		251247.5	251247.5
	Heating	140,112.1	175,140.1	3,701.7	4,625.5	1/21 09	40.82	0.00537	0		167846.1	167846.1
THERMAL ZONE A-2-1	Cooling	251,247.5	288,934.6	11,348.7	13,050.2	8/21 16	76.93	0.00819	0		251247.5	251247.5
	Heating	167,846.1	209,807.7	4,403	5,504.9	1/21 09	40.82	0.00537	0		167846.1	167846.1
THERMAL ZONE B-1-1	Cooling	88,642.3	101,938.6	4,028	4,631.9	8/21 14	78.26	0.00819	0		251247.5	251247.5
	Heating	36,419	45,523.8	1,063.7	1,330.7	1/21 08	40.82	0.00537	0		167846.1	167846.1
THERMAL ZONE B-2-1	Cooling	95,276.4	109,567.9	4,331	4,979.4	8/21 15	78.1	0.00819	0		251247.5	251247.5
	Heating	45,057.5	56,321.8	1,324.3	1,654.8	1/21 08	40.82	0.00537	0		167846.1	167846.1
THERMAL ZONE B-3-1	Cooling	95,031.7	109,286.4	4,318.3	4,966.7	8/21 15	78.1	0.00819	0		251247.5	251247.5
	Heating	46,380.7	57,975.9	1,364.6	1,705.7	1/21 08	40.82	0.00537	0		167846.1	167846.1
THERMAL ZONE B-4-1	Cooling	92,928.7	106,867.9	4,222.9	4,856.5	8/21 15	78.1	0.00819	0		251247.5	251247.5
	Heating	50,866.4	63,583	1,500.2	1,875.2	1/21 08	40.82	0.00537	0		167846.1	167846.1

### Lesson 2: DESIGN ALTERNATE 1 – Triple glazing with low-e with Building Model Creator

67	In the <b>Project</b> workspace	
68	In the Project Information palette	
69	Select the “ <i>Load calculation</i> ” design alternative and click on the <b>Copy</b> button	
70	Rename the <b>Design Alternative 1</b> to	<i>“Triple Glazing 1”</i>
71	Go to the <b>Buildings</b> Workspace	
72	In the Create/Edit Buildings ribbon menu	
73	In the Create/Edit Building palette	
74	In the <b>Buildings</b> tab	
75	Click the <b>Edit</b> button next to <b>Building Constructions</b>	
<div style="border: 1px solid gray; padding: 5px;"> <p>Templates</p> <p>Building Constructions: <input type="text" value="DefaultBuildingConstructions"/> <span style="float: right;">▼ Edit</span></p> </div>		
76	Change the four window constructions dropdowns from “ <i>GLAZ_DoublePane</i> ” to	<i>“GLAZ_TriplePane-LowE”</i>
77	Click on <b>Save Changes</b> , then	
78	Click on <b>Save</b> on the <b>Create/Edit Building</b> palette	
79	Click on the <b>File</b> Menu	
80	Click on the <b>SaveAs</b> Button to save the current model.	
81	Set <b>File name</b> to	<i>“BasicTraining2”</i>
82	Go to the <b>Simulate</b> Workspace	
83	In the <b>EnergyPlus</b> ribbon menu	
84	In the lower right palette	
85	Click on <b>Run Simulation</b>	
86	Wait for simulation to finish	
87	Click on the <b>Reports</b> Workspace	
88	Click on Select SimRun in the ribbon and select the first two annual SimRuns	



- 89 Select the **Envelope Summary Report**
- 90 Turn on **Scrolling/Zoom/Page Change** in the **Synchronize** section in the ribbon





- 91 Investigate the **Envelope Summary** report and scroll down to the **Fenestration** section to verify that the window types are correct.

Fenestration				
	Construction	Area of One Opening (ft.2)	Area of Openings (ft.2)	U-Factor (BTU/h-ft <sup>2</sup> -°F)
SPACE A-1-1-WINDOW A.1.1.1	GLAZ_DOUBLEPANE	88	88	0.525
SPACE A-1-1-WINDOW A.1.1.2	GLAZ_DOUBLEPANE	88	88	0.525
SPACE A-1-1-WINDOW A.1.1.3	GLAZ_DOUBLEPANE	88	88	0.525
SPACE A-1-1-WINDOW A.1.1.4	GLAZ_DOUBLEPANE	88	88	0.525
SPACE A-1-1-WINDOW A.1.1.5	GLAZ_DOUBLEPANE	88	88	0.525

Fenestration				
	Construction	Area of One Opening (ft.2)	Area of Openings (ft.2)	U-Factor (BTU/h-ft <sup>2</sup> -°F)
SPACE A-1-1-WINDOW A.1.1.1	GLAZ_TRIPLEPANE WITH LOWE	89	89	0.289
SPACE A-1-1-WINDOW A.1.1.2	GLAZ_TRIPLEPANE WITH LOWE	89	89	0.289
SPACE A-1-1-WINDOW A.1.1.3	GLAZ_TRIPLEPANE WITH LOWE	89	89	0.289
SPACE A-1-1-WINDOW A.1.1.4	GLAZ_TRIPLEPANE WITH LOWE	89	89	0.289
SPACE A-1-1-WINDOW A.1.1.5	GLAZ_TRIPLEPANE WITH LOWE	89	89	0.289


- 92 Select the **Project Summary** report
- 93 Compare the **Net Site Energy Intensity** between the two runs to access the energy savings for the triple glazing.



**Lesson 3: DESIGN ALTERNATE 2 – Triple glazing with low-e with Measure**

- 94 In the **Project** workspace
- 95 In the **Project Information** palette
- 96 Select the **“Load calculation”** design alternative and click on the **Copy** button
- 97 Rename the **Design Alternative 1** to *“Triple Glazing 2”*
- 98 Go to the **Simulate** Workspace

99	In the <b>EnergyPlus</b> ribbon menu	
100	In the right palette	
101	Click on the plus in front of <b>Envelope</b> . Click on the plus left of <b>Fenestration</b> Locate the “Add low-e triple glazing to all windows” Measure	



102	Either select the measure and drag and drop it unto the configuration or select the measure and press the <b>Add selected measures</b> button	
103	Click on the <b>File Menu</b>	
104	Click on the <b>SaveAs</b> Button to save the current model.	
105	Set <b>File name</b> to	<i>“BasicTraining3”</i>
106	Go to the <b>Simulate Workspace</b>	
107	In the <b>EnergyPlus</b> ribbon menu	
108	In the lower right palette	
109	Click on <b>Run Simulation</b>	
110	Wait for the simulation to finish	
111	Click on the <b>Reports Workspace</b>	
112	Click on <b>Select SimRun</b> and select the both triple glazing alternative SimRuns	
113	Select the <b>Envelope Summary Report</b>	
114	Turn on Synchronization of Scrolling/Zoom/Page Change in the ribbon.	
115	Investigate the Envelope Summary report and scroll down to the Fenestration section to verify that the window types are correct. The screenshot below compares identical windows.	

Fenestration				
	Construction	Area of One Opening (ft <sup>2</sup> )	Area of Openings (ft <sup>2</sup> )	U-Factor (BTU/h-ft <sup>2</sup> -°F)
SPACE A-1-1-WINDOW A.1.1.1	GLAZ_TRIPLEPANE WITH LOWE	89	89	0.289
SPACE A-1-1-WINDOW A.1.1.2	GLAZ_TRIPLEPANE WITH LOWE	89	89	0.289
SPACE A-1-1-WINDOW A.1.1.3	GLAZ_TRIPLEPANE WITH LOWE	89	89	0.289
SPACE A-1-1-WINDOW A.1.1.4	GLAZ_TRIPLEPANE WITH LOWE	89	89	0.289
SPACE A-1-1-WINDOW A.1.1.5	GLAZ_TRIPLEPANE WITH LOWE	89	89	0.289

Fenestration				
	Construction	Area of One Opening (ft <sup>2</sup> )	Area of Openings (ft <sup>2</sup> )	U-Factor (BTU/h-ft <sup>2</sup> -°F)
SPACE A-1-1-WINDOW A.1.1.1	GLAZ_TRIPLEPANE WITH LOWE	90	90	0.288
SPACE A-1-1-WINDOW A.1.1.2	GLAZ_TRIPLEPANE WITH LOWE	90	90	0.288
SPACE A-1-1-WINDOW A.1.1.3	GLAZ_TRIPLEPANE WITH LOWE	90	90	0.288
SPACE A-1-1-WINDOW A.1.1.4	GLAZ_TRIPLEPANE WITH LOWE	90	90	0.288
SPACE A-1-1-WINDOW A.1.1.5	GLAZ_TRIPLEPANE WITH LOWE	90	90	0.288

**Lesson 4: DESIGN ALTERNATE 3 – Air to air heat pump**

116	In the <b>Project</b> workspace	
117	In the Project Information palette	
118	Select the <b>"Triple Glazing 2"</b> design alternative and click on copy	
119	Rename the <b>Design Alternative 1</b> to	<i>"Air to Air Heat Pump"</i>
120	Go to the <b>Systems</b> Workspace	
121	In the <b>Systems Creator</b> ribbon menu	
122	Select the <b>Template Name</b> dropdown as	<i>"HeatPump AirToAir COP3.8"</i>
123	Set the dropdown for Zone HVAC Groups and Air loops to	<i>"One per zone"</i>
124	Click on <b>Generate Systems</b>	

All existing systems will be replaced

Template Name:  Generate Systems Save as Template Delete Systems

	Grouping	Primary Templates
Zone HVAC Group:	<input type="text" value="One Per Zone"/>	<input type="text" value="AT_Unctrl"/>
SHW Group:	<input type="text" value="One Per Building"/>	<input type="text" value="None Selected"/>
Air loop:	<input type="text" value="One Per Zone"/>	<input type="text" value="HPAta COP 3.8_BT"/>
VRF loop:	<input type="text" value="One Per Project"/>	<input type="text" value="None Selected"/>
Hot water loop:	<input type="text" value="One Per Project"/>	<input type="text" value="None Selected"/>
Chilled water loop:	<input type="text" value="One Per Project"/>	<input type="text" value="None Selected"/>
Mixed water loop:	<input type="text" value="One Per Project"/>	<input type="text" value="None Selected"/>
SHW Loop:	<input type="text" value="One Per Project"/>	<input type="text" value="None Selected"/>
Condenser loop:	<input type="text" value="One Per Project"/>	<input type="text" value="None Selected"/>
Steam loop:	<input type="text" value="One Per Project"/>	<input type="text" value="None Selected"/>

```

    graph LR
      Air-1 --> ZHG-1
      Air-2 --> ZHG-2
      Air-3 --> ZHG-3
      Air-4 --> ZHG-4
      Air-5 --> ZHG-5
      Air-6 --> ZHG-6
    
```

125	Click on the <b>File</b> Menu	
126	Click on the <b>SaveAs</b> Button to save the current model.	
127	Set <b>File</b> name to	<i>"BasicTraining4"</i>
128	Go to the <b>Simulate</b> Workspace	
129	In the <b>EnergyPlus</b> ribbon menu	
130	In the lower right palette	
131	Click on <b>Run Simulation</b>	
132	Wait for simulation to finish	
133	Click on the <b>Reports</b> Workspace	
134	Select the <b>Project Summary</b> Report.	
135	In the <b>Project Summary</b> report verify that unmet load hours are under control and that the Net Site Energy Intensity is about 52 kBtu/ft2.	






## Project Summary

Air to Air HeatPump | Configuration 1 | SimRun1

Calculated at YMD=2018.08.15 16:07

Project Name: BasicTraining3\_simp

Simergy Version: v3 (SP2)

Building Summary		Weather Summary		Building Performance	
Building Type		Location	San Francisco Intl Ap CA USA	Unmet cooling load hours (Occupied)	AVG 0 This Building 1 hours
Conditioned Floor Area	36,122 ft <sup>2</sup>	Weather File	USA_CA_San.Francisco.IntlAP:724940_TMY3	Less hours 	More hours
Total Building Area	36,122 ft <sup>2</sup>	Latitude	N 37° 37'	0 hours	600 hours
Gross Wall Area	32,779 ft <sup>2</sup>	Time Zone	GMT -8.0 Hours	Unmet heating load hours (Occupied)	AVG 0 This Building 0 hours
Window-Wall Ratio	43.31 %	Summer Design Dry Bulb Temperature (1%)	78.3 °F	Less hours 	More hours
Average Plug Load Density	0.83 W/ft <sup>2</sup>	Summer Design Wet Bulb Temperature (1%)	75 °F	0 hours	600 hours
Average Lighting Density	1.25 W/ft <sup>2</sup>	Winter Design Dry Bulb Temperature (99%)	40.8 °F	Net Site Energy Intensity	This Building 52.22 kBtu/ft <sup>2</sup>
Peak Occupancy	301	User Defined		Uses less energy 	Uses more energy
Total Outdoor Air Flow	5,216.00 cfm	Summer Design Day Dry Bulb Temperature		0 kBtu/ft <sup>2</sup>	350 kBtu/ft <sup>2</sup>
Cooling Specific Air Flow	33,542.00 cfm	Coincident Design Day Wet Bulb Temperature			
Heating Specific Air Flow	13,349.00 cfm	Winter Design Day Dry Bulb Temperature			
Site Peak Cooling Load	802,135.4 Btu/h				
Site Peak Heating Load	482,214.36 Btu/h				

Site Performance		Site Power Generation		Site Thermal Energy Recovery	
Net Source EUI	165.4 kBtu/ft <sup>2</sup>	Fuel-Fired Power Generation	0 kWh	Water-Side Heat Recovery	0 kWh
Annual Electrical Consumption	552,814 kWh	High Temperature Geothermal	0 kWh	Air to Air Heat Recovery Cooling	0 kWh
Annual Peak Electrical Demand	150.6 KW	Photovoltaic Power	0 kWh	Air to Air Heat Recover Heating	0 kWh
Annual Gas Consumption	0 kBtu	Wind Power	0 kWh	High-Temperature Geothermal	0 kWh
Annual Water Consumption	0 ft <sup>3</sup>	Net Decrease in On-Site Storage	0 kWh	Solar Water Thermal	0 kWh
Operating Cooling Load	109,938 kBtu	Sub-Total On Site Electric	0 kWh	Solar Air Thermal	0 kWh
Operating Heating Load	1,799 kBtu	Electricity Coming From Utility	552,813 kWh	Total On-Site Thermal Sources	0 kWh
		Surplus Electricity To Utility	0 kWh		
		Net Electricity From Utility	552,813 kWh		
		Total Electric Sources	552,813 kWh		


### Lesson 5: DESIGN ALTERNATE 4 – ASHRAE-7

136	In the <b>Project</b> workspace	
137	In the Project Information palette	
138	Select the <b>"Triple Glazing 2"</b> design alternative and click on copy	
139	Rename the Design Alternative 4 to	<b>"ASHRAE-7"</b>
140	Go to the <b>Systems</b> Workspace	
141	In the <b>Systems Creator</b> ribbon menu	
142	Select the <b>Template Name</b> dropdown as	<b>"ASHRAE-7"</b>
143	Set the dropdown for Zone HVAC Groups and Air loops to	<b>"One per zone"</b>
144	Click on <b>Generate Systems</b>	

All existing systems will be replaced

Template Name: ASHRAE7-VAVwReheat Generate Systems Save as Template Delete Systems

Grouping	Primary Templates
Zone HVAC Group: <span style="border: 1px solid #ccc; padding: 2px;">One Per Zone</span>	<span style="border: 1px solid #ccc; padding: 2px;">ASHRAE-AT_VAV_ReH-Wtr_TC</span>
SHW Group: <span style="border: 1px solid #ccc; padding: 2px;">One Per Building</span>	<span style="border: 1px solid #ccc; padding: 2px;">None Selected</span>
Air loop: <span style="border: 1px solid #ccc; padding: 2px; background-color: #e1f5fe;">One Per Zone</span>	<span style="border: 1px solid #ccc; padding: 2px;">ASHRAE-VAV_wtrC_wtrH_DT</span>
VRF loop: <span style="border: 1px solid #ccc; padding: 2px;">One Per Project</span>	<span style="border: 1px solid #ccc; padding: 2px;">None Selected</span>
Hot water loop: <span style="border: 1px solid #ccc; padding: 2px;">One Per Project</span>	<span style="border: 1px solid #ccc; padding: 2px;">ASHRAE-Boil(2)_HW_VSD</span>
Chilled water loop: <span style="border: 1px solid #ccc; padding: 2px;">One Per Project</span>	<span style="border: 1px solid #ccc; padding: 2px;">ASHRAE-Chl(2)_VC_Elec_EIR_VS</span>
Mixed water loop: <span style="border: 1px solid #ccc; padding: 2px;">One Per Project</span>	<span style="border: 1px solid #ccc; padding: 2px;">None Selected</span>
SHW Loop: <span style="border: 1px solid #ccc; padding: 2px;">One Per Project</span>	<span style="border: 1px solid #ccc; padding: 2px;">None Selected</span>
Condenser loop: <span style="border: 1px solid #ccc; padding: 2px;">One Per Project</span>	<span style="border: 1px solid #ccc; padding: 2px;">ASHRAE-CoolTwr(2)_2SP_CSD</span>
Steam loop: <span style="border: 1px solid #ccc; padding: 2px;">One Per Project</span>	<span style="border: 1px solid #ccc; padding: 2px;">None Selected</span>








145	Click on the <b>File</b> Menu	
146	Click on the <b>SaveAs</b> Button to save the current model.	
147	Set <b>File name</b> to	<i>"BasicTraining5"</i>
148	Go to the <b>Simulate</b> Workspace	
149	In the <b>EnergyPlus</b> ribbon menu	
150	In the lower right palette	
151	Click on <b>Run Simulation</b>	
152	Wait for simulation to finish	
153	Click on the <b>Reports</b> Workspace	
154	Select the <b>Project Summary</b> Report.	
155	In the <b>Project Summary</b> report verify that unmet load hours are under control and compare the Net Site Energy Intensity value to that of the heat pump alternative.	

### Project Summary

ASHRAE-7 | Configuration 1 | SimRun1 Calculated at YMD=2018.08.15 16:24  
 Project Name: BasicTraining3.simp Simergy Version: v3 (SP2)

Building Summary		Weather Summary		Building Performance	
Building Type		Location	San Francisco Intl Ap CA USA	Unmet cooling load hours (Occupied)	AVG 6 This Building 128 hours
Conditioned Floor Area	36,122 ft <sup>2</sup>	Weather File	USA_CA_San.Francisco.Intl.AP.724940_TMY3	Less hours 	More hours
Total Building Area	36,122 ft <sup>2</sup>	Latitude	N 37° 37'	0 hours	600 hours
Gross Wall Area	32,779 ft <sup>2</sup>	Time Zone	GMT -8.0 Hours	Unmet heating load hours (Occupied)	AVG 1 This Building 9 hours
Window-Wall Ratio	43.31 %	Summer Design Dry Bulb Temperature (1%)	78.3 °F	Less hours 	More hours
Average Plug Load Density	0.83 W/ff	Summer Design Wet Bulb Temperature (1%)	75 °F	0 hours	600 hours
Average Lighting Density	1.25 W/ff	Winter Design Dry Bulb Temperature (99%)	40.8 °F	Net Site Energy Intensity	This Building 42.48 kBtu/ff
Peak Occupancy	301	User Defined		Uses less energy 	Uses more energy
Total Outdoor Air Flow	5,216.00 cfm	Summer Design Day Dry Bulb Temperature		0 kBtu/ff	350 kBtu/ff
Cooling Specific Air Flow	33,542.00 cfm	Coincident Design Day Wet Bulb Temperature			
Heating Specific Air Flow	13,349.00 cfm	Winter Design Day Dry Bulb Temperature			
Site Peak Cooling Load	802,135.4 Btu/h				
Site Peak Heating Load	482,214.36 Btu/h				

Site Performance		Site Power Generation		Site Thermal Energy Recovery	
Net Source EUI	125.9 kBtu/ft <sup>2</sup>	Fuel-Fired Power Generation	0 kWh	Water-Side Heat Recovery	0 kWh
Annual Electrical Consumption	405,622 kWh	High Temperature Geothermal	0 kWh	Air to Air Heat Recovery Cooling	0 kWh
Annual Peak Electrical Demand	134.5 kW	Photovoltaic Power	0 kWh	Air to Air Heat Recover Heating	0 kWh
Annual Gas Consumption	150,492 kBtu	Wind Power	0 kWh	High-Temperature Geothermal	0 kWh
Annual Water Consumption	10,587.3 ft <sup>3</sup>	Net Decrease in On-Site Storage	0 kWh	Solar Water Thermal	0 kWh
Operating Cooling Load	56,276 kBtu	Sub-Total On Site Electric	0 kWh	Solar Air Thermal	0 kWh
Operating Heating Load	150,492 kBtu	Electricity Coming From Utility	405,623 kWh	Total On-Site Thermal Sources	0 kWh
		Surplus Electricity To Utility	0 kWh		
		Net Electricity From Utility	405,623 kWh		
		Total Electric Sources	405,623 kWh		

156	Select the <b>Project Comparison</b> Report.	
157	Click on <b>Select SimRun</b> and select the ASHREA-7 and the Air to Air HeatPump alternative SimRuns. Between the two alternatives and see that the internal loads are identical (as expected) and that overall the water based systems is using less energy.	

## Project Comparison

Air to Air HeatPump | Configuration 1 | SimRun1

Calculated at YMD=2018.08.15 16:07

Project Name: BasicTraining3.smp

Simergy Version: v3 (SP2)

### Alternative Energy End Use and Demand Comparison

Energy Usage	Air to Air HeatPump   Configuration 1   SimRun1		ASHRAE-7   Configuration 1   SimRun1	
	Total Energy End Use (kWh)	Electric Demand (KW)	Total Energy End Use (kWh)	Electric Demand (KW)
Space Cooling	32,244	56.8	16,506	32.23
Space Heating	528	0	44,139	0
Heat Rejection	0	0	983	3.18
Fans	229,386	26.19	86,122	25.33
Pumps	0	0	11,353	6.09
Humidification	0	0	0	0
Heat Recovery	0	0	0	0
Interior Receptacles	99,694	26.99	99,694	26.99
Exterior Receptacles	0	0	0	0
Interior Lighting	190,961	40.67	190,961	40.67
Exterior Lighting	0	0	0	0
Service Water Heating	0	0	0	0
Rafrigeration	0	0	0	0
Site Power Generation	0	0	0	0
<b>Grand Total</b>	<b>552,814</b>	<b>150.65</b>	<b>449,761</b>	<b>134.49</b>